

N61165.AR.005516
CNC CHARLESTON
5090.3a

LETTER REGARDING SOUTH CAROLINA DEPARTMENT OF HEALTH AND
ENVIRONMENTAL CONTROL REVIEW OF RELEASE REPORT RECEIVED 8 DECEMBER
1993 FOR BUILDING 1288 FUEL OIL TANK CNC CHARLESTON SC
01/31/1994
SOUTH CAROLINA DEPARTMENT OF HEALTH AND ENVIRONMENTAL CONTROL

Commissioner: Douglas E. Bryant

Board: Richard E. Jabbour, DDS, Chairman
Robert J. Stripling, Jr., Vice Chairman
Sandra J. Molander, Secretary

William E. Applegate, III,
John H. Burriss
Tony Graham, Jr., MD
John B. Pate, MD

Promoting Health, Protecting the Environment

January 31, 1994

R. E. Dewitt
Director, Occupational Safety,
Health and Environmental Office
Department of the Navy
Naval Station
Charleston, SC 29408-5000

RE: Release Report received December 8, 1993
Charleston Naval Base, Building 1288 Fuel Oil Tank, GWPD #A-10-AA-16307
Charleston County

New File

Dear Mr. Dewitt:

The Ground Water Protection Division (GWPD) of the South Carolina Department of Health and Environmental Control (SCDHEC) has reviewed the referenced release report for a heating oil (fuel oil) underground Storage tank (UST). The report indicates soil contamination is present. The GWPD requests an assessment plan to define the soil and potential ground-water contamination at the referenced UST. A Hydrogeologic Assessment Guidance Document has been enclosed for your review. The requested Assessment Plan should be submitted to my attention on or before April 29, 1994.

On all future correspondence concerning this site, please reference GWPD #A-10-AA-16307. If you have any questions, please contact me at (803) 734-5328.

Sincerely,

Timothy A. Mettlen
Timothy A. Mettlen, Hydrogeologist
Assessment and Development Section
Ground Water Protection Division
Bureau of Drinking Water Protection

tam/cnb1288.rel

ENC: Hydrogeologic Assessment Guidance Document

CC: Christine Coker, Trident District EQC